

GOVERNMENT OF PAKISTAN MINISTRY OF MARITIME AFFAIRS (PORTS & SHIPPING WING)

No. 1(2)/CE&SS-2021

Karachi, the 10th June, 2021

CIRCULAR NO. 02 /2021

Subject:

Guidelines for the Maintenance and Inspections of Fixed Carbon Dioxide Fire Extinguishing System.

IMO vide Circular -M SC.1/Circ. 1318/Rev.1 has approved revised Guidelines for the maintenance and inspections of fixed carbon dioxide fire-extinguishing system.

- 2. The amendments represent a significant increase in the hydrostatic test regime for CO₂ cylinders. While the (10%) ten percent of the total number of CO₂ cylinders shall still be hydrostatically tested at the 10-year inspection, the M SC .1/Circ. 1318/R ev.1 requires that all cylinders to be tested before the 20-year anniversary. Further, all cylinders (100%) to be tested at every 10-year anniversary thereafter.
- 3. The revised requirements states that -

"The hydrostatic test date of all storage containers should be checked. High-pressure cylinders should be subjected to periodical tests at intervals not exceeding 10 years. At the 10-year inspection, at least 10% of the total number provided should be subjected to an internal inspection and hydrostatic test. If one or more cylinders fail, a total of 50% of the onboard cylinders should be tested. If further cylinders fail, all cylinders should be tested. Before the 20-year anniversary and every 10-year anniversary thereafter, all cylinders should be subjected to a hydrostatic test".

- 4. When the CO₂ cylinders are removed for the hydrostatic test, they should be replaced such that the quantity of fire-extinguishing medium continues to satisfy the requirements of 2.2.1 of chapter 5 of the FSS Code, subject to SOLA S regulation II-2/14.2.
- 5. Further, at least once every five years, an internal inspection of all control valves to be performed (aligned with the requirements of M SC.1/Circ.1432).

6. Copy of M SC.1/Circ.1318/Rev.1 is attached. Shipowners / managers and masters are advised to take note of the revised requirements and ensure compliance.

Enclosure:

1. M SC.1/Circ. 1318/Rev.1, Dated 25 May 2021.

(WAMIQ ABRAR SIDDIQUI)

Chief Engineer & Ships Surveyor
Directorate General Ports & Shipping
Ministry of Maritime Affairs
Karachi – Pakistan

DISTRIBUTION:

- 1. Pakistan National Shipping Corporation
- 2. The Director General (P&S).
- 3. The Chief Nautical Surveyor, P&S Wing, Karachi.
- 4. The Principal Officer, MMD, Karachi.
- 5. Engineer & Ship Surveyor MMD, Karachi.



4 ALBERT EMBANKMENT **LONDON SE1 7SR**

Telephone: +44 (0)20 7735 7611

Fax: +44 (0)20 7587 3210

MSC.1/Circ.1318/Rev.1

25 May 2021

REVISED GUIDELINES FOR THE "TAINTENANCE THE INSPECTIONS OF FIXED CARIS DI DIOXIDE E-EXTINGUI

- The Maritime Safety Committee, at its eighty-sixth session (27 May to 5 June 2009), having considered the proposal by the Sub-Committee on Fire Protection, at its fifty-third session, approved Guidelines for the maintenance and inspections of ixed carbon dioxide fire-extinguishing systems (MSC.1/Circ.1318).
- In order to address the need to clarify the hydrostatic testing regime for high-pressure CO₂ cylinders and to align the relevant requirements in the Guidelines with those in the Revised quidelines for the maintenance and inspection of fire protection sy times and appliances (MSC.1/Circ 1:32), the Committee, at its 103rd session (5 to 14 is by 2021), approved amendments to the above-mentioned Guidelines, prepared by the Sub-Committee on Ship Systems and Equipment, at its seventh session, with a view to dissemination as MSC.1/Circ.1318/Rev.1. The text of the Revised guidelines for the maintenance and inspections of fixed carbon dioxide fire-extinguishing systems is set out in the annex.
- 3 Member Governments are invited to apply the annexed Revised guidelines when inspecting fixed carbon dioxide fire-extinguishing systems on board all ships and bring them to the attention of ship designers, shipowners, equipment manufacturers, and other parties concerned.
- This circular supersedes MSC.1/Circ.1318.



ANNEX

REVISED GUIDELINES FOR THE MAINTENANCE AND INSPECTIONS OF FIXED CARBON DIOXIDE FIRE-EXTINGUISHING SYSTEMS

1 General

These Revised guidelines provide the minimum recommended level of maintenance and inspections for fixed carbon dioxide fire-extinguishing systems on all ships and are intended to demonstrate that the system is kept in good working order as specified in COLAS regulation II-2/14.2.1.2. These Revised guidelines are intended to suppleme the fire-extinguishing system manufacturer's approved maintenance instructions. Certain maintenance procedures and inspections may be performed by competent crewmembers, while others should be performed by persons specially trained in the maintenance of such systems. The onboard maintenance plan should indicate which parts of the recommended inspections and maintenance should be completed by trained | sonnel.

2 Safety

Whenever carbon dioxide fire-extinguishing systems are subjected to inspection or maintenance, strict safety precautions should be followed to prevent the possibility that individuals performing or witnessing the activities are placed at risk. Prior to performing any work, a safety plan should be developed to account for all personnel and establish an effective communications system between the inspection personnel and the on-duty crew. Measures to avoid accidental discharges such as lonking or removing the operating arms from directional valves, or shutting and lockit the system block valve should be taken as the initial procedure for the protection of personnel performing any maintenance or inspections. All personnel should be notified of the impending activities before work is begun.

3 Maintenance and inspection plan

Fixed carbon dioxide fire-extinguishing systems should be kept in good working order and readily available for immediate use. Maintenance and inspections should be carried out in accordance with the ship's maintenance plan having due regard to ensuring the reliability of the system. The onboard maintenance plan should be included in the ship's safety management system and should be based on the system manufacturer's recommendations including:

- .1 maintenance and inspection procedures and instructions;
- .2 required schedules for periodic maintenance and inspections;
- .3 listing of recommended spare parts; and
- records of inspections and maintenance, including corrective actions taken to maintain the system in operable condition.

4 Monthly inspections

- 4.1 At least every 30 days a general visual inspection should be made of the overall system condition for obvious signs of damage, and should include verification that:
 - .1 all stop valves are in the closed position;
 - .2 all releasing controls are in the proper position and readily accessible for immediate use:
 - .3 all discharge piping and pneumatic tubing is intact and has not been damaged;
 - .4 all high-pressure cylinders are in place and properly secured; and
 - .5 the alarm devices are in place and do not appear damaged.
- 4.2 In addition, on low pressure systems the inspections should verify that:
 - the pressure gauge is reading in the normal range;
 - .2 the liquid level indicator is reading within the proper level;
 - .3 the manually operated storage tank main service valve is secured in the open position; and
 - .4 the vapour supply line valve is secured in the open position.

5 Annual inspections

The following minimum level of maintenance and inspections should be carried out in accordance with the system manufacturer's instructions and safety precautions:

- the boundaries of the protected space should be visually inspected to confirm that no modifications have been made to the enclosure that have created uncloseable openings that would render the system ineffective;
- .2 all storage containers should be visually inspected for any sins of damage, rust or loose mounting hardware. Cylinders that are leang, corroded, dented or bulging should be hydrostatically retested or repla ad;
- .3 system piping should be visually inspected to check for damage, loose supports and corrosion. Nozzles should be inspected to ensure they have not been obstructed by the storage of spare parts or a new installation of structure or machinery;
- the manifold should be inspected to verify that all flexible discharge hoses and fittings are properly tightened; and
- all entrance doors to the protected space should close properly and should have warning signs, which indicate that the space is protected by a fixed carbon dioxide system and that personnel should evacuate immediately if the alarms sound. All remote releasing controls should be checked for clear operating instructions and indication as to the space served.

6 Minimum recommended maintenance

- 6.1 At least biennially (intervals of 2 years ± 3 months) in passenger ships or at each intermediate, periodical or renewal survey¹ in cargo ships, the following maintenance should be carried out (to assist in carrying out the recommended maintenance, examples of service charts are set out in the appendix):
 - .1 all high-pressure cylinders and pilot cylinders should be weighed or have their contents verified by other reliable means to confirm that the available charge in each is above 90% of the nominal charge. Cylinders containing less than 90% of the nominal charge should be refilled. The liquid level of low pressure storage tanks should be checked to verify that the required amount of carbon dioxide to protect the largest hazard is available;
 - the hydrostatic test date of all storage containers should be checked. High-pressure cylinders should be subjected to periodical tests at intervals not exceeding 10 years. At the 0-year inspection, at least 10% of the total number provided should be subjected to an internal inspection and hydrostatic test². If one or more cylinders fail, a total of 50% of the onboard cylinders should be tested. If further cylinders fail, all cylinders should be tested. Before the 20-year anniversary and every 10-year anniversary thereafter, all cylinders should be subjected to a hydrostatic test. Flexible hoses should be replaced at the intervals recommended by the manufacturer and not exceeding every 10 years. When cylinders are removed for testing, the cylinders should be replaced such that the quantity of fire-extinguishing medium con inues to satisfy the requirements of 2.2.1 of chapter 5 of the FSS Code, subject to SOLAS regulation II-2/14.2; and
 - .3 the discharge piping and nozzles should be tested to verify that they are not blocked. The test should be performed by isolating the discharge piping from the system and flowing dry air or nitrogen from test cylinders or suitable means through the piping.
- 6.2 At least biennially (intervals of 2 years ± 3 months) in passenger ships or at each renewal survey¹ in cargo ships, the following maintenance should be carried out by service technicians/ specialists trained to standards accepted by the Administration:
 - .1 where possible, all activating heads should be removed from the cylinder valves and tested for correct functioning by applying full working pressure through the pilot lines.

In cases where this is not possible, pilot lines should be disconnected from the cylinder valves and blanked off or connected together and tested with full working pressure from the release station and checked for leakage.

In both cases this should be carried out from one or more release stations when installed. If manual pull cables operate the remote release controls, they should be checked to verify the cables and corner pulleys are in good condition and freely move and do not require an excessive amount of travel to activate the system;

Refer to the Survey Guidelines under the Harmonized System of Survey and Certification (HSSC), 2019 (resolution A.1140(31)).

Refer to standard ISO 18119:2018 – Gas cylinders – Seamless steel and seamless aluminium-alloy gas cylinders and tubes – Periodic inspection and testing.

- all cable components should be cleaned and adjusted as necessary, and the cable connectors should be properly tightened. If the remote release controls are operated by pneumatic pressure, the tubing should be checked for leakage, and the proper charge of the remote releasing station pilot gas cylinders should be verified. All controls and warning devices should function normally, and the ine delay, if fitted should prevent the discharge of gas for the required time period; and
- .3 after completion of the work, the system should be returned to service. All releasing controls should be verified in the proper position and connected to the correct control valves. All pressure switch interlocks should be reset and returned to service. All stop valves should be in the closed position.

7 Five-year service

At least once every five years, internal inspection of all control valves should be performed.

APPENDIX

EXAMPLE SERVICE CHARTS

HIGH PRESSURE CO2 SYSTEM

Date:	Name of ship/unit:	IMO No.:	
£			

Technical description

No.	Text :	Value
1	Manufacturer	
2	Number of main cylinders	
3	Main cylinders capacity (each)	
4	Number of pilot cylinders	
5	Pilot cylinder capacity (each)	
6	Number of distribution lines	
7	Oldest cylinder pressure test date	
8	Protected space(s)	
9	Date flexible hoses fitted/renewed	

Description of inspection/Tests

No.	Description	Carried	Not	Not	Comment
- 6.2.		out	carried out	applicable	
1	Release controls and distribution valves secured to prevent accidental discharge				
2	Contents in main cylinders checked by weighing				
3	Contents in main cylinders checked by liquid level indicator				
4	Contents of pilot cylinders checked				
5	All cylinder valves visually inspected				
6	All cylinder clamps and connections checked for				
	tightness				
7	Manifold visually inspected				
8	Manifold tested for leakage, by applying dry				
	working air				
9	Main valve and distribution valves visually				
	inspected				
10	Main valve and distribution valves tested for				
	operation				
-	Time delay devices tested for correct setting*				
12	Remote release system visually inspected				
	Remote release system tested		-		
14	Servo tubing/pilot lines pressure tested at]	
	maximum working pressure and checked for				
	leakages and blockage				
15	Manual pull cables, pulleys, gang releases tested,				
	serviced and tightened/adjusted as necessary				
16	Release stations visually inspected				

MSC.1/Circ.1318/Rev.1 Annex, page 6

No.	Description	Carried out	Not carried out	Not applicable	Comment
17	Warning alarms (audible/visual) tested				
18	Fan stop tested				
19	10% of cylinders and pilot cylinder/s pressure tested every 10 years. All cylinders and pilot cylinder/s pressure tested before the 20-year anniversary and every 10-year anniversary thereafter	3.7 1.7 2.7 2.7 2.7 2.7 2.7 2.7 2.7 2.7 2.7 2			
20	Internal inspection of all control valves performed at least once every five years				
21	Distribution lines and nozzles blown through, by applying dry working air				
22	All doors, hinges and locks inspected				
23	All instruction and warning signs on installation inspected				
24	All flexible hoses renewed and check valves in manifold visually inspected every 10 years				
25	Release controls and distribution valves reconnected and system put back in service				
26	Inspection date tags attached				

If fitted as part of the CO₂ system.

ĻOV	N PRESSURE CO2 SYSTEM				
Da	te: Name of ship/unit:		O No.:		
		· · · · · · · · · · · · · · · · · · ·			
Tec	hnical description				
No.	Text Representation of the second sec	Val	ue		
1	Manufacturer				
2	No. of tanks			· · · · · · · · · · · · · · · · · · ·	
3	Tanks capacity (tonnes)				
4	Number of pilot cylinders				
5	Pilot cylinder capacity (each)		· · · ·		
6	Number of distribution lines				
7	Protected space(s)				_

Description of inspection/Tests

No.	Description	Carried out	Not carried	Not applicable	Comment
			out	1 1 1 1 1 1 1 1 1	
1	Tank main service valve closed and secured to				
<u> </u>	prevent accidental discharge				
2	Distribution valves verified closed				
3	Check correct function of level indicator				
4	Contents of CO₂ tank checked by tank level indicator				,

No.	Description	Carried out	Not carried out	Not applicable	Comment
5	Contents of CO ₂ tank checked by riser tube reading				
6	Contents of CO ₂ tank checked by level control valve		3.00		
7	Supports of tank inspected	t			
8	Insulation on tank inspected				* ***
9	Safety valves of tank inspected				
10	Safety valves of tank tested				
11	Contents of pilot cylinders checked				
12	Start/stop function of cooling compressors tested				
13	All connected electrical alarms and indicators tested				
14	Main manifold valve inspected				
15	Internal inspection of all control valves performed at least once every five years				
16	Main manifold valve tested				
17	Distribution valves inspected				
	Distribution valves tested				
19	Release stations inspected				
	Total flooding release mechanism inspected				
21	Total flooding release mechanism tested				
	Time delay devices tested for correct setting	=	·	l	
	Warning alarms tested		*******		
	Fan stop tested				
25	Distribution lines and nozzles inspected				
26	Distribution lines and nozzles tested			 	
27	Distribution lines and nozzles blown through				
	All doors, hinges and locks inspected*		* "-		
	All instruction plates inspected				
30	Tank main service valve reopened and secured open				
	System put back in service				
	Inspection date tags attached				

If fitted as part of the CO₂ system.